
***MOJAVE DESERT
AIR QUALITY MANAGEMENT DISTRICT***

Federal Operating Permit 104701849

For:

High Desert Power Project, LLC

Facility:

High Desert Power Project, LLC

Issue Date: November 4, 2016

Expiration Date: November 4, 2021

Issued by:

Brad Poiriez

Executive Director/

Air Pollution Control Officer



14306 PARK AVENUE, VICTORVILLE, CALIFORNIA 92392

PHONE: (760) 245-1661 • FAX: (760) 245-2022 • EMAIL: PERMITTING@MDAQMD.CA.GOV

PERMIT REVISIONS

November 19, 2018 Administrative Permit Change (RNB)

Part I, page I-4, changed to reflect a change in Responsible Official to Claude Couvillion, Vice President of Operations

November 7, 2016 Permit Renewal (RNB)

October 21, 2014 Administrative Permit Change (RNB)

Part I, page I-7: Removed permit B009188. Equipment has been removed and District permit cancelled.

Part III, page III-29: Permit conditions 12 & 13 which pertain to compliance testing have been clarified and consolidated into one new condition (#12)

Part III, page III-37: Removed reference to permit B009188. Equipment has been removed and District permit cancelled.

October 3, 2011 Administrative Permit Change (by: Samuel J Oktay, PE); changed SCR manufacturer on equipment reference to Cormetech from Babcock Hitachi. Permits affected are: C005272, C005273, and C005274; pages affected I-6, and III-33. Rule 442 updated, page affected II-13.

March 21, 2011 Administrative Permit Renewal (by: Samuel J Oktay, PE); Revised Rule 1113 references, Page II-17 through II-18; added Rule SIP History Reference, Page VII-51; Added requirements of 40 CFR Part 68; Risk Management Program on Page II-21. Revised Condition 9; Page III-29. Permit is revised 05-11-11 with a re-issue date effective September 18, 2011 and a new expiration date of September 18, 2016. During the interim period, the previous Title V permit, with an expiration date of September 18, 2011, remains in effect.

October 07, 2008 Administrative Permit Modification described as follows:

Page I-4 and Pages III-35 through III-38 changed to reflect latest permit requirements for E008159 and E008665. (by Bill Weese)

May 06, 2008 Administrative Permit Modification described as follows:

Page I-4 changed to reflect a change in Responsible Official to Todd S. Jonas, Vice President. (by Bill Weese)

TABLE OF CONTENTS

	<u>Page</u>
Part I	Introductory Information.....I-4 through I-7
Part II	Applicable Requirements and Emissions Limitations.....II-8 through II-25
Part III	Monitoring, Recordkeeping, Reporting and Testing Requirements.....III-26 through III-41
Part IV	Standard Federal Operating Permit Conditions.....IV-42 through IV-44
Part V	Operational Flexibility Provisions.....V-45 through V-46
Part VI	Title IV Acid Rain Permit.....VI-47 through VI-54
Part VII	Conventions, Abbreviations, and Definitions.....VII-55 through VII -62

PART I INTRODUCTORY INFORMATION

A. FACILITY IDENTIFYING INFORMATION:

Owner/Company Name: HIGH DESERT POWER PROJECT, LLC

Owner Mailing Address: HIGH DESERT POWER PROJECT, LLC
19000 Perimeter Road
Victorville, CA 92394

Facility Name: HIGH DESERT POWER PROJECT, LLC

Facility Location: HIGH DESERT POWER PROJECT, LLC
19000 Perimeter Road
Victorville, CA 92394

MDAQMD Federal Operating Permit Number: 104701849

MDAQMD Company Number: 1047

MDAQMD Facility Number: 01849

Responsible Official: Claude Couvillion
Title: Vice President of Operations
Phone Number: (760) 686-4415

Facility "Site" Contact #1: Jon Boyer
Title: Environmental Manager
Phone Number: (760) 530-2312
(760) 530-2300

Nature of Business: Electric Power Generation
SIC Code: 4911 – Electric Power Generation
ORIS Code: 55518
Facility Location: UTM (Km) 466.545E / 3828.060N

High Desert Power Project, LLC, is a 750 MW output natural gas fired combined cycle power generating plant located in Victorville, California. The plant uses three F-Class Westinghouse combustion turbine generators (CTGs) with dedicated heat recovery steam generators (HRSGs) to produce electricity. Inlet air to the CTGs is filtered and conditioned, with cooling water supported by a mechanical draft wet cooling tower. Compressed air and natural gas are mixed and combusted in the turbine combustion chamber. Lean pre-mixed air and low NOx combustors are used to minimize NOx formation during combustion. Exhaust gas heat from each CTG is recovered in a dedicated HRSG, in which steam is produced to drive a dedicated condensing steam turbine generator (STG) connected to an electric power generator. Each HRSG is equipped with a natural gas-fired duct burner to provide supplementary firing during high ambient temperatures to maintain constant steam production to the STG.

A Selective Catalytic Reduction (SCR) system to control NOx emissions and high temperature oxidation catalyst to control CO and VOC emissions are located inside each HRSG.

The STG exhaust steam is routed for condensing to a surface condenser with water pumped in from a twelve-cell wet cooling tower by circulating water pumps. Make-up water to the circulating water system is clarified raw water supply. Blowdown from the cooling tower side stream treatment system drains into a wastewater brine storage tank. Treated water is recycled to the cooling tower or discharged to underground injection wells.

One Cummins diesel-fired internal combustion engine is used to drive an emergency firepump. One Caterpillar diesel-fired internal combustion engine is used to drive an emergency power generator. Two silos containing soda ash and lime provide chemical feed for the cooling tower blowdown system.

FACILITY PERMITTED EQUIPMENT

<u>MDAQMD PERMIT NUMBER</u>	
<u>B005266</u>	<u>COMBUSTION TURBINE GENERATOR 3F-1, consisting of:</u> Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e).
<u>B005267</u>	<u>COMBUSTION TURBINE GENERATOR 3F-2, consisting of:</u> Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e)

<u>B005268</u>	<u>COMBUSTION TURBINE GENERATOR 3F-3</u> , consisting of: Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e).
<u>B005269</u>	<u>DUCT BURNER 3F-1</u> : COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005266, maximum heat input of 160 MMBtu/hr.
<u>B005270</u>	<u>DUCT BURNER 3F-2</u> : COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005267, maximum heat input of 160 MMBtu/hr.
<u>B005271</u>	<u>DUCT BURNER 3F-3</u> : COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005268, maximum heat input of 160 MMBtu/hr.
<u>C005272</u>	<u>SCR UNIT 3F-1</u> : a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005266 and an ammonia injection system.
<u>C005273</u>	<u>SCR UNIT 3F-2</u> : a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005267 and an ammonia injection system.
<u>C005274</u>	<u>SCR UNIT 3F-3</u> : a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005268 and an ammonia injection system.
<u>C005275</u>	<u>OXIDATION CATALYST 3F-1</u> : High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005266 designed to minimize emissions of VOC and CO.
<u>C005276</u>	<u>OXIDATION CATALYST 3F-2</u> : High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005267 designed to minimize emissions of VOC and CO.
<u>C005277</u>	<u>OXIDATION CATALYST 3F-3</u> : High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005268 designed to minimize emissions of VOC and CO.
<u>B005278</u>	<u>COOLING TOWER</u> : Water circulation, treatment and handling equipment and air circulation equipment. Cooling Tower Manufacturer; GEA Integrated Cooling Technologies, Inc. Serial Number; 544246-12B-WCF.
T010620	<u>SILOS, BULK STORAGE</u> : Two US Filter Zimpro Products Model T-1 bulk chemical handling station cylindrical silos (soda ash and hydrated lime) each 32 feet 11 1/8" H and 12' diameter that are part of the cooling tower blowdown system. Each silo is equipped with a passive bin vent

	containing 125 square feet of bag filters that handle 500 cfm of pneumatic loading flow (for an air to cloth ratio of 4:1).
E008159	<u>FIRE WATER PUMP, DIESEL</u> : One Cummins, Diesel fired internal combustion engine Model No. 6BTA 5.9 FI and Serial No. 46100208, After Cooled, Turbo Charged, producing 182 bhp with 6 cylinders at 1785 rpm while consuming a maximum of 9 gal/hr. This equipment powers a ITTAC Fire Pump Model No. 10 x 8 x 17F rated at 2000 GPM.
E008665	<u>IC ENGINE, EMERGENCY GENERATOR</u> : One Caterpillar, Diesel fired internal combustion engine Model No. 3516 and Serial No. 1H202373, Turbo Charged, After Cooled, producing 2848 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 136 gal/hr. This equipment powers a Caterpillar Generator rated at 2000 kW(e).

PART II
FACILITYWIDE APPLICABLE REQUIREMENTS; EMISSIONS
LIMITATIONS; MONITORING, RECORDKEEPING,
REPORTING AND TESTING REQUIREMENTS; COMPLIANCE
CONDITIONS; COMPLIANCE PLANS

A. **REQUIREMENTS APPLICABLE TO ENTIRE FACILITY AND EQUIPMENT:**

1. A permit is required to operate this facility.
[Rule 203 - *Permit to Operate*]
2. The equipment at this facility shall not be operated contrary to the conditions specified in the District Permit to Operate.
[Rule 203 - *Permit to Operate*]
3. The Air Pollution Control Officer (APCO) may impose written conditions on any permit.
[Rule 204 - *Permit Conditions*]
4. Commencing work or operation under a permit shall be deemed acceptance of all the conditions so specified.
[Rule 204 - *Permit Conditions*]
5. Posting of the Permit to Operate is required on or near the equipment or as otherwise approved by the APCO/District.
[Rule 206 - *Posting of Permit to Operate*]
6. Owner/Operator shall not willfully deface, alter, forge, or falsify any permit issued under District rules.
[Rule 207 - *Altering or Falsifying of Permit*]
7. Permits are not transferable.
[Rule 209 - *Transfer and Voiding of Permit;*]
8. The APCO may require the Owner/Operator to provide and maintain such facilities as are necessary for sampling and testing.
[Rule 217 - *Provision for Sampling And Testing Facilities*]
9. The equipment at this facility shall not require a District permit or be listed on the Title V permit if such equipment is listed in Rule 219 and meets the applicable criteria contained

in Rule 219 (B). However, any exempted insignificant activities/equipment are still subject to all applicable facility-wide requirements.

[SIP Pending: Rule 219 - *Equipment Not Requiring a Written Permit*]

10. The Owner/Operator of this facility shall obtain a Federal Operating Permit for operation of this facility.
[Rule 221 - *Federal Operating Permit Requirement*]
11. Owner/Operator shall pay all applicable MDAQMD permit fees.
[Rule 301 - *Permit Fees*]
12. Owner/Operator shall pay all applicable MDAQMD Title V Permit fees.
[Rule 312 - *Fees for Federal Operating Permits*]
13. Stack and point source visible emissions from this facility, of any air contaminant (including smoke) into the atmosphere, shall not equal or exceed Ringelmann No. 1 for a period or periods aggregating more than three minutes in any one hour:
 - (a) While any unit is fired on Public Utilities Commission (PUC) grade natural gas, Periodic Monitoring for combustion equipment is not required to validate compliance with the Rule 401 Visible Emissions limit. However, the Owner/Operator shall comply with the recordkeeping requirements stipulated elsewhere in this permit regarding the logging of fuel type, amount, and suppliers' certification information.
 - (b) While any unit is fired on diesel fuel, Periodic Monitoring, in addition to required recordkeeping, is required to validate compliance with Rule 401 Visible Emissions limit as indicated below:
 - (i). Reciprocating engines equal or greater than 1000 horsepower, firing on only diesel with no restrictions on operation, a visible emissions inspection is required every three (3) months or during the next scheduled operating period if the unit ceases firing on diesel/distillate within the 3-month time frame.
 - (ii). Diesel Standby and emergency reciprocating engines using California low sulfur fuels require no additional monitoring for opacity.
 - (iii). Diesel/Distillate-Fueled Boilers firing on California low sulfur fuels require a visible emissions inspection after every 1 million gallons diesel combusted, to be counted cumulatively over a 5-year period.
 - (iv). On any of the above, if a visible emissions inspection documents opacity, an U.S. Environmental Protection Agency (EPA) Method 9 "Visible Emissions Evaluation" shall be completed within 3 working days, or during the next scheduled operating period if the unit ceases firing on diesel/distillate within the 3 working day time frame.

[Rule 204 - *Permit Conditions*]
[Rule 401 - *Visible Emissions*]

14. Owner/Operator is limited to use of the following quality fuels for fuel types specified elsewhere in this permit: PUC quality natural gas fuel - sulfur compounds shall not exceed 800 parts per million (ppm) calculated as hydrogen sulfide at standard conditions; diesel fuel - sulfur content shall not exceed 0.0015 percent by weight. Compliance with Rule 431 fuel sulfur limits is assumed for PUC quality natural gas fuel and CARB certified diesel fuel. Records shall be kept on-site and available for review by District, state, or federal personnel at any time. The sulfur content of non-CARB certified diesel fuel shall be determined by use of American Society for Testing and Materials (ASTM) method D 2622-82 or ASTM method D 2880-71, or equivalent.
[40 CFR 70.6 (a)(3)(i)(B) - *Periodic Monitoring Requirements*]
[Rule 431 - *Sulfur Content of Fuels*;
15. Emissions of fugitive dust from any transport, handling, construction, or storage activity at this facility shall not be visible in the atmosphere beyond the property line of the facility.
[Rule 403 - *Fugitive Dust*;
16. Owner/Operator shall comply with the applicable requirements of Rule 403.2 unless an “Alternative PM₁₀ Control Plan” (ACP) pursuant to Rule 403.2(G) has been approved.
[Rule 403.2 - *Fugitive Dust Control for the Mojave Desert Planning Area*]
17. Owner/Operator shall not discharge into the atmosphere from this facility, particulate matter (PM) except liquid sulfur compounds, in excess of the concentration at standard conditions, shown in Rule 404, Table 404 (a).
 - (a) Where the volume discharged is between figures listed in the table the exact concentration permitted to be discharged shall be determined by linear interpolation.
 - (b) This condition shall not apply to emissions resulting from the combustion of liquid or gaseous fuels in steam generators or gas turbines.
 - (c) For the purposes of this condition, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.[Rule 404 - *Particulate Matter Concentration*]
18. Owner/Operator shall not discharge into the atmosphere from this facility, solid PM including lead and lead compounds in excess of the rate shown in Rule 405, Table 405(a).
 - (a) Where the process weight per hour is between figures listed in the table, the exact weight of permitted discharge shall be determined by linear interpolation.
 - (b) For the purposes of this condition, emissions shall be averaged over one complete cycle of operation or one hour, whichever is the lesser time period.

[Rule 405 - *Solid Particulate Matter, Weight*]

19. Owner/Operator shall not discharge into the atmosphere from this facility, from any single source of emissions whatsoever, sulfur compounds, which would exist as a liquid or gas at standard conditions, calculated as sulfur dioxide (SO₂), greater than or equal to 500 ppm by volume.

[Rule 406 - *Specific Contaminants*]

20. Owner/Operator shall not discharge into the atmosphere from this facility, carbon monoxide (CO) exceeding 2000 ppm measured on a dry basis, averaged over a minimum of 15 consecutive minutes.

- (a) The provisions of this condition shall not apply to emissions from internal combustion engines.

[Rule 407 - *Liquid and Gaseous Air Contaminants*]

21. Owner/Operator shall not build, erect, install, or use any equipment at this facility, the use of which, without resulting in a reduction in the total release of air contaminants to the atmosphere, reduces or conceals an emission that would otherwise constitute a violation of Chapter 3 (commencing with Section 41700) of Part 4, of Division 26 of the Health and Safety Code or of District Rules.

- (a) This condition shall not apply to cases in which the only violation involved is of Section 41700 of the Health and Safety Code, or of District Rule 402.

[Rule 408 - *Circumvention*]

22. Owner/Operator shall not discharge into the atmosphere from this facility from the burning of fuel, combustion contaminants exceeding 0.23 gram per cubic meter (0.1 grain per cubic foot) of gas calculated to 12 percent of carbon dioxide (CO₂) at standard conditions averaged over a minimum of 25 consecutive minutes.

[Rule 409 - *Combustion Contaminants*;

23. APCO, at his/her discretion, may refrain from enforcement action against an Owner/Operator of any equipment that has violated a technology-based emission limitation, including but not limited to conditions contained in any permit issued by the District establishing such emission limitation, provided that a Breakdown has occurred and:

- (a) Any breakdown that results in emissions exceeding a technology-based emission limitation is reported to the District within one hour of such breakdown or within one hour of the time a person knew or reasonably should have known of the occurrence of such breakdown; and

- (b) An estimate of the repair time is provided to the District as soon as possible after

- the report of the breakdown; and
- (c) All reasonable steps are immediately taken to minimize the levels of emissions and to correct the condition leading to the excess emissions.
 - (d) The equipment is operated only until the end of a cycle or twenty-four (24) hours, whichever is sooner, at which time it shall be shut down for repairs unless a petition for an emergency variance has been filed with the clerk of the Hearing Board in accordance with Regulation V.
 - (e) If the breakdown occurs outside normal District working hours, the intent to file an emergency variance shall be transmitted to the District in a form and manner prescribed by the APCO.

[Rule 430 - *Breakdown Provisions*]

24. Owner/Operator of this facility shall not discharge into the atmosphere emissions in excess of the following from VOC containing materials or from organic solvents which are not VOCs unless such emissions have been reduced by at least 85%:
- (a) VOCs from all VOC containing materials, Emissions Units, equipment or processes subject to this rule, in excess of 540 kilograms (1,190 pounds) per month per Facility.
 - (b) a non-VOC organic solvent in excess of 272 kilograms (600 pounds) per day as calculated on a thirty (30) day rolling average.
 - (c) The provisions of this condition shall not apply to:
 - (1) The manufacture of organic solvents, or the transport or storage of organic solvents, or the transport or storage of materials containing organic solvents.
 - (2) The emissions of VOCs from VOC-containing materials or equipment which are subject to the rules of Regulation IV or which are exempt from air pollution control requirements by said rules.
 - (3) The spraying or other employment of organic solvents as insecticides, pesticides or herbicides.
 - (4) The use of equipment or materials for which other requirements are specified in source specific rules of Regulation XI after the compliance dates specified in such source specific rules.
 - (5) The use of 1-1-1 Trichloroethane.
 - (6) Aerosol products

[Rule 442 – *Usage of Solvents*]

25. Owner/Operator shall not set open outdoor fires unless in compliance with Rule 444. Outdoor fires burned according to an existing District permit are not considered “open outdoor fires” for the purposes of Rule 444 (reference Rule 444(B)(10)).

[Rule 444 – *Open Outdoor Fires*]

26. Owner/Operator of this facility shall comply with the Organic Solvent Degreasing Operations requirements of Rule 1104 when engaged in wipe cleaning, cold solvent cleaning, and/or vapor cleaning (degreasing) operations for metal/non-metal parts/products. These requirements are listed as follows:
- (a) All degreasers shall be equipped with a cover, which reduces solvent evaporation and minimizes disturbing the vapor zone.
 - (b) A permanent, conspicuous label summarizing the applicable operating requirements contained in Rule 1104. In lieu of a label, operating instructions may be posted near the degreaser where the operators can access the proper operating requirements of this rule.
 - (c) Cold Solvent Degreasers - Freeboard Requirements:
 - (i) Cold solvent degreasers using only low volatility solvents, which are not agitated, shall operate with a freeboard height of not less than 6 inches.
 - (ii) Cold solvent degreasers using only low volatility solvents may operate with a freeboard ratio equal to or greater than 0.50 when the cold solvent degreaser has a cover, which remains closed during the cleaning operation.
 - (iii) Any cold solvent degreasers using solvent which is agitated, or heated above 50°C (120°F) shall operate with a freeboard ratio equal to or greater than 0.75.
 - (iv) A water cover may be used as an acceptable control method to meet the freeboard requirements, when the solvent is insoluble in water and has a specific gravity greater than one.
 - (d) Cold Solvent Degreasers - Cover Requirements:
 - (i) Cold solvent degreasers using high volatility solvent shall have a cover that is a sliding, rolling or guillotine (bi-parting) type, which is designed to easily open and close without disturbing the vapor zone.
 - (e) Cold Solvent Degreasers - Solvent Level Identification:
 - (i) A permanent, conspicuous mark locating the maximum allowable solvent level conforming to the applicable freeboard requirements.
 - (f) All Degreasers shall comply with the following operating requirements:
 - (i) Any solvent cleaning equipment and any emission control device shall be operated and maintained in strict accord with the recommendations of the manufacturer.
 - (ii) Degreasers shall not be operating with any detectable solvent leaks.
 - (iii) All solvent, including waste solvent and waste solvent residues, shall be stored in closed containers at all times. All containers for any solvent(s) shall have a label indicating the name of the solvent/material they contain.
 - (iv) Waste solvent and any residues shall be disposed of by one of the following

- methods: a commercial waste solvent reclamation service licensed by the State of California; **or** a federally or state licensed facility to treat, store or dispose of such waste; **or** the originating facility may recycle the waste solvent and materials in conformance with requirements of Section 25143.2 of the California Health and Safety Code.
- (v) Degreasers shall be covered to prevent fugitive leaks of vapors, except when processing work or to perform maintenance.
 - (vi) Solvent carry-out shall be minimized by the following methods:
 - (a) Rack workload arranged to promote complete drainage
 - (b) Limit the vertical speed of the power hoist to 3.3 meters per minute (11 ft/min) or less when such a hoist is used.
 - (c) Retain the workload inside of the vapor zone until condensation ceases.
 - (d) Tip out any pools of solvent remaining on the cleaned parts before removing them from the degreaser if the degreasers are operated manually.
 - (e) Do not remove parts from the degreaser until the parts are visually dry and not dripping/leaking solvent. (This does not apply to an emulsion cleaner workload that is rinsed with water within the degreaser immediately after cleaning.)
 - (vii) The cleaning of porous or absorbent materials such as cloth, leather, wood or rope is prohibited.
 - (viii) Except for sealed chamber degreasers, all solvent agitation shall be by either pump recirculation, a mixer, or ultrasonics.
 - (ix) The solvent spray system shall be used in a manner such that liquid solvent does not splash outside of the container. The solvent spray shall be a continuous stream, not atomized or shower type, unless, the spray is conducted in a totally enclosed space, separated from the environment.
 - (x) For those degreasers equipped with a water separator, no solvent shall be visually detectable in the water in the separator.
 - (xi) Wipe cleaning materials containing solvent shall be kept in closed containers at all times, except during use.
 - (xii) A degreaser shall be located so as to minimize drafts being directed across the cleaning equipment, the exposed solvent surface, or the top surface of the vapor blanket.
 - (xiii) A method for draining cleaned material, such as a drying rack suspended above the solvent and within the freeboard area, shall be used so that the drained solvent is returned to the degreaser or container.
- (g) Rule 442 Applicability: Any solvent using operation or facility which is not subject to the source-specific Rule 1104 shall comply with the provisions of Rule 442. Any

solvent using operation or facility which is exempt from all or a portion of the volatile organic compound (VOC) limits, equipment limits or the operational limits of Rule 1104 shall be subject to the applicable provisions of Rule 442.

- (h) Solvent Usage Records. Owner/Operator subject to Rule 1104 or claiming any exemption under Rule 1104, Section (E), shall comply with the following requirements:
- (1) Maintain and have available during an inspection, a current list of solvents in use at the facility which provides all of the data necessary to evaluate compliance, including the following information separately for each degreaser, as applicable:
 - (i) product name(s) used in the degreaser, and
 - (ii) the mix ratio of solvent compounds mixtures of solvents are used, and
 - (iii) VOC content of solvent or mixture of compounds as used, and
 - (iv) the total volume of the solvent(s) used for the facility, on a monthly basis, and
 - (v) the name and total volume applied of wipe cleaning solvent(s) used, on a monthly basis.
 - (2) Additionally, for any degreaser utilizing an add-on emission control device/system as a means of complying with provisions of Rule 1104 shall, on a monthly basis, maintain records of key system operating and maintenance data. Such data are recorded for the purpose of demonstrating continuous compliance during periods of emission producing activities. The data shall be recorded in a manner as prescribed by the District.
 - (3) Documentation shall be maintained on site of the disposal or on-site recycling of any waste solvent or residues.
 - (4) Records shall be retained (at facility) and available for inspection by District, state or federal personnel for the previous 5-year period as required by this Title V / Federal Operating Permit (Reference Rule 1203(D)(1)(d)(ii)).

[Rule 1104 - *Organic Solvent Degreasing Operations*]

27. Owner/Operator's use of *Architectural Coatings* at this facility shall comply with the applicable requirements of Rule 1113, including the VOC limits specified in Rule 1113, part C, Table of Standards, as listed below:

Coating Category	Limit
Primary Coatings	
Flat Coatings	50
Nonflat Coatings	100
Nonflat-High Gloss Coatings	150
Specialty Coatings	
Aluminum Roof Coatings	400
Basement Specialty Coatings	400
Bituminous Roof Coatings	50
Bituminous Roof Primers	350
Bond Breakers	350
Concrete Curing Compounds	350
Concrete/Masonry Sealers	100
Driveway Sealers	50
Dry Fog Coatings	150
Faux Finishing Coatings	350
Fire Resistive Coatings	350
Floor Coatings	100
Form-Release Compounds	250
Graphic Arts Coatings (Sign Paints)	500
High Temperature Coatings	420
Industrial Maintenance Coatings	250
Low Solids Coatings	120 _a
Magnesite Cement Coatings	450
Mastic Texture Coatings	100
Metallic Pigmented Coatings	500
Multi-Color Coatings	250
Pre-Treatment Wash Primers	420
Primers, Sealers, and Undercoaters	100
Reactive Penetrating Sealers	350
Recycled Coatings	250
Roof Coatings	50
Rust Preventative Coatings	250
Shellacs:	
Clear	730
Opaque	550
Specialty Primers, Sealers, and Undercoaters	100
Stains	250

Stone Consolidants	450
Swimming Pool Coatings	340
Traffic Marking Coatings	100
Tub and Tile Refinish Coatings	420
Waterproofing Membranes	250
Wood Coatings	275
Wood Preservatives	350
Zinc-Rich Primers	340

[Rule 1113 - *Architectural Coatings*]

28. Owner/Operator's use of *Wood Products Coatings* at this facility shall comply with the applicable requirements of Rule 1114, including the VOC limits specified in Rule 1114, part C, Table of Standards, as listed below:

(1) VOC Content of Coatings & Adhesives

(a) Any Owners and/or Operators of Wood Products Coating Application Operations shall not apply any Coating or Adhesive to a Wood Product which has a VOC Content, including any VOC-containing material added to the original Coating supplied by the manufacturer, which exceeds the applicable limit specified below, unless emissions to the atmosphere are controlled by air pollution abatement equipment with an Overall Control Efficiency of at least 85 percent. Any Coating subject to this rule that meets either of the two VOC Content limit formats (grams per liter or pounds per gallon [lb/gal]) is in compliance with this subsection.

(i)

LIMITS

Grams of VOC Per Liter of Coating,
 Less Water and Less Exempt Compounds (VOC Content)

Coating	Current Limit g/L (lb/gal)	On and After 7/1/97		On and After 7/1/2005
		Column I or g/L (lb/gal)	Column II g/L (lb/gal)	g/L (lb/gal)
Clear Sealers	680 (5.7)	550 (4.6)	680 (5.7)	275 (2.3)
Clear Topcoat	680 (5.7)	550 (4.6)	275 (2.3)	275 (2.3)

		On and After 7/1/97		On and After 7/1/2005
Pigmented Primers, Sealers and Undercoats	600 (5.0)	550 (4.6)	600 (5.0)	275 (2.3)
Pigmented Topcoats	600 (5.0)	550 (4.6)	275 (2.3)	275 (2.3)

Effective July 1, 1997, a person or facility shall use Coatings on Wood Products that comply with either all VOC Content limits in Column I or all VOC Content limits in Column II. A person or facility that applies a Pigmented Primer, Sealer or Undercoat, but not a Clear Topcoat or Pigmented Topcoat, to a Wood Product shall be subject to column I for that product.

- (ii) Notwithstanding the requirements of subsection (C)(1)(a)(i), a person or facility that applies a topcoat and a primer, sealer or undercoat to a Shutter may, until July 1, 2005, choose to comply with the VOC Content limits specified below for that Shutter:

(b) **LIMITS**
 Grams of VOC Per Liter of Coating,
Less Water and Less Exempt Compounds (VOC Content)

Coating	g/L (lb/gal)
Clear Sealers	275 (2.3)
Clear Topcoat	680 (5.7)
Pigmented Primers, Sealers & Undercoats	275 (2.3)
Pigmented Topcoats	600 (5.0)

(c) **LIMITS**
 Grams of VOC Per Liter of Coating,
Less Water and Less Exempt Compounds (VOC Content)

Coating	Current Limit g/L (lb/gal)	On and After 7/1/97	On and After 7/1/2005
		g/L (lb/gal)	g/L (lb/gal)

		On and After 7/1/97	On and After 7/1/2005
Fillers	500 (4.2)	500 (4.2)	275 (2.3)
High-Solid Stains	700 (5.8)	550 (4.6)	350 (2.9)
Inks	500 (4.2)	500 (4.2)	500 (4.2)
Mold-Seal Coatings	750 (6.3)	750 (6.3)	750 (6.3)
Multi-Colored Coatings	685 (5.7)	685 (5.7)	275 (2.3)
Low-Solids Stains, Toners and Washcoats	800 (6.7)	480 (4.0)	120 (1.0)
Adhesives	250 (2.1)	250 (2.1)	250 (2.1)

[Rule 1114 - *Wood Products Coating Operations*]

29. Owner/Operator's use of *Metal Parts and Products Coatings* at this facility shall comply with the applicable requirements of Rule 1115, including the VOC limits specified in Rule 1115, as listed below:

Owner/Operator shall not apply to metal parts and products any coatings, including any VOC-containing materials added to the original coating supplied by the manufacturer, which contain VOC in excess of the limits specified below unless emissions to the atmosphere are controlled to an equivalent level by air pollution abatement equipment with a capture and control system Combined Efficiency of at least 85 percent:

LIMITS

(Grams of VOC Per Liter of Coating, Less Water and Less Exempt Compounds)

<u>Coating</u>	<u>Air Dried</u>		<u>Baked</u>	
	g/L	(lb/gal)	g/L	(lb/gal)
General	420	(3.5)	360	(3.0)
Military Specification	420	(3.5)	360	(3.0)
Etching Filler	420	(3.5)	420	(3.5)
Solar-Absorbent	420	(3.5)	360	(3.0)
Heat-Resistant	420	(3.5)	360	(3.0)
High-Gloss	420	(3.5)	360	(3.0)
Extreme High-Gloss	420	(3.5)	360	(3.0)
Metallic	420	(3.5)	420	(3.5)

Extreme Performance	420	(3.5)	360	(3.0)
Prefabricated Architectural				
Component	420	(3.5)	275	(2.3)
Touch Up	420	(3.5)	360	(3.0)
Repair	420	(3.5)	360	(3.0)
Silicone-Release	420	(3.5)	420	(3.5)
High Performance				
Architectural	420	(3.5)	420	(3.5)
Camouflage	420	(3.5)	420	(3.5)
Vacuum-Metalizing	420	(3.5)	420	(3.5)
Mold-Seal	420	(3.5)	420	(3.5)
High-Temperature	420	(3.5)	420	(3.5)
Electric-Insulating Varnish	420	(3.5)	420	(3.5)
Pan-Backing	420	(3.5)	420	(3.5)
Pretreatment Wash Primer	420	(3.5)	420	(3.5)
Clear Coating	520	(4.3)	520	(4.3)

[Rule 1115 - *Metal Parts and Products Coating Operations*]

30. Owner/Operator shall comply with all requirements of the District’s Title V Program, MDAQMD Rules 1200 through 1210.
 [Regulation XII - *Federal Operating Permits*]
31. Owner/Operator shall comply with all requirements of 40 CFR Part 68; Risk Management Program.

FACILITY-WIDE MONITORING, RECORDKEEPING, AND REPORTING REQUIREMENTS:

1. Any data and records generated and/or kept pursuant to the requirements in this federal operating permit (Title V Permit) shall be kept current and on site for a minimum of five (5) years from the date generated. Any records, data, or logs shall be supplied to District, state, or federal personnel upon request.
 [40 CFR 70.6(a)(3)(ii)(B); Rule 1203(D)(1)(d)(ii)]
2. Any Compliance/Performance testing required by this Federal Operating Permit shall follow the administrative procedures contained in the District's *Compliance Test Procedural Manual*. Any required annual Compliance and/or Performance Testing shall be accomplished by obtaining advance written approval from the District pursuant to the

District's *Compliance Test Procedural Manual*. All emission determinations shall be made as stipulated in the *Written Test Protocol* accepted by the District. When proposed testing involves the same procedures followed in prior District approved testing, then the previously approved *Written Test Protocol* may be used with District concurrence.
[Rule 204 - *Permit Conditions*]

3. Owner/Operator of permit units subject to Comprehensive Emissions Inventory Report / Annual Emissions Determinations for District, state, and federal required Emission Inventories shall monitor and record the following for each unit:
 - (a) The cumulative annual usage of each fuel type. The cumulative annual usage of each fuel type shall be monitored from utility service meters, purchase or tank fill records.
 - (b) Fuel suppliers' fuel analysis certification/guarantee including fuel sulfur content shall be kept on site and available for inspection by District, state or federal personnel upon request. The sulfur content of diesel fuel shall be determined by use of ASTM method D2622-82, or (ASTM method D 2880-71, or equivalent). Vendor data meeting this requirement are sufficient.

[40 CFR 70.6(a)(3)(B) – *Periodic Monitoring Requirements*]

[Rule 204 - *Permit Conditions*]

[Federal Clean Air Act: §110(a)(2)(F, K & J); §112; §172(c)(3); §182(a)(3)(A & B); §187(a)(5); § 301(a) and in California Clean Air Act, Health and Safety Code §§39607 and §44300 et seq.]

4. (a) Owner/Operator shall submit Compliance Certifications as prescribed by Rule 1203(F)(1) and Rule 1208, in a format approved by MDAQMD. Compliance Certifications by a Responsible Official shall certify the truth, accuracy and completeness of the document submitted and contain a statement to the effect that the certification is based upon information and belief, formed after a reasonable inquiry; the statements and information in the document are true, accurate, and complete.
[40 CFR 70.6(c)(5)(i); Rule 1208; Rule 1203(D)(1)(vii-x)]
- (b) Owner/Operator shall include in any Compliance Certification the methods used for monitoring such compliance.
[40 CFR 70.6(c)(5)(ii); Rule 1203(D)(1)(g)(viii)]
- (c) Owner/Operator shall comply with any additional certification requirements as specified in 42 United States Code (U.S.C.) §7414(a)(3), Recordkeeping, Inspections, Monitoring and Entry (Federal Clean Air Act §114(a)(3)) and 42 U.S.C. §7661c(b), Permit Requirements and Conditions (Federal Clean Air Act §503(b)), or in regulations promulgated thereunder.
[Rule 1203 (D)(1)(g)(x)]

- (d) On an *annual* basis, of any given year, Owner/Operator shall submit a *Compliance Certification Report* to the APCO/District pursuant to District Rule 1203 on the following schedule:

Report covering November 4 – November 3	Due by December 1
---	-------------------

Each report shall be certified to be true, accurate, and complete by “The Responsible Official” and a copy of this annual report shall also be contemporaneously submitted to the EPA Region IX Administrator. Compliance Certification Form/Format shall be obtained from MDAQMD Compliance Section.
 [40 CFR 72.90.a and Rule 1203 (D)(1)(g)(v - x)]

5. Owner/Operator shall submit, on a semi-annual basis, a *Monitoring Report* to the Air Pollution Control Officer (APCO) / District. Each *Monitoring Report* shall be submitted each semi-annual compliance period on the following schedule:

Report covering May 5 – November 3	Due by December 1
Report covering November 4 – May 4	Due by June 1

This *Monitoring Report* shall be certified to be true, accurate, and complete by “The Responsible Official” and shall include the following information and/or data:

- (a) Summary of deviations from any federally enforceable requirement in this permit.
- (b) Summary of all emissions monitoring and analysis methods required by any Applicable Requirement / federally - enforceable requirement.
- (c) Summary of all periodic monitoring, testing or record keeping (including test methods sufficient to yield reliable data) to determine compliance with any Applicable Requirement / federally - enforceable requirement that does not directly require such monitoring.

An alternate Monitoring Report format may be used upon prior approval by MDAQMD.
 [Rule 1203(D)(1)(e)(i)]

6. Owner/Operator shall promptly report all deviations from Federal Operating Permit requirements including, but not limited to, any emissions in excess of permit conditions, deviations attributable to breakdown conditions, and any other deviations from permit conditions. Such reports shall include the probable cause of the deviation and any corrective action or preventative measures taken as a result of the deviation. [Rule 1203(D)(1)(e)(ii) and Rule 430(C)]

Prompt reporting shall be determined as follows:

- (a) For deviations involving emissions of air contaminants in excess of permit conditions including but not limited to those caused by a breakdown, prompt

reporting shall be within one hour of the occurrence of the excess emission or within one hour of the time a person knew or reasonably should have known of the excess emission. Documentation and other relevant evidence regarding the excess emission shall be submitted to the District within sixty (60) days of the date the excess emission was reported to the District. [SIP Pending: Rule 430 - Breakdown Provisions as amended 12/21/94 and submitted 2/24/95]

- (b) For other deviations from permit conditions not involving excess emissions of air contaminants shall be submitted to the District with any required monitoring reports at least every six (6) months. [Rule 1203(D)(1)(e)(i)]

7. If any facility unit(s) should be determined not to be in compliance with any federally-enforceable requirement during the 5-year permit term, then Owner/Operator shall obtain a *Schedule of Compliance* approved by the District Hearing Board pursuant to the requirements of MDAQMD Regulation 5 (Rules 501 - 518). In addition, Owner/Operator shall submit a *Progress Report* on the implementation of the *Schedule of Compliance*. The *Schedule of Compliance* shall contain the information outlined in (b), below. The *Progress Report* shall contain the information outlined in (c), below. The *Schedule of Compliance* shall become a part of this Federal Operating Permit by administrative incorporation. The *Progress Report* and *Schedule of Compliance* shall comply with Rule 1201(I)(3)(iii) and shall include:

- (a) A narrative description of how the facility will achieve compliance with such requirements; and
- (b) A *Schedule of Compliance* which contains a list of remedial measures to be taken for the facility to come into compliance with such requirements, an enforceable sequence of actions, with milestones, leading to compliance with such requirements and provisions for the submission of *Progress Reports* at least every six (6) months. The *Schedule of Compliance* shall include any judicial order, administrative order, and/or increments of progress or any other schedule as issued by any appropriate judicial or administrative body or by the District Hearing Board pursuant to the provisions of Health & Safety Code §42350 et seq.; and
- (c) *Progress Reports* submitted under the provisions of a *Schedule of Compliance* shall include: Dates for achieving the activities, milestone, or compliance required in the schedule of compliance; and dates when such activities, milestones or compliance were achieved; and an explanation of why any dates in the schedule of compliance were not or will not be met; and any preventive or corrective measures adopted due to the failure to meet dates in the schedule of compliance. [Rule 1201 (I)(3)(iii); Rule 1203 (D)(1)(e)(ii); Rule 1203 (D)(1)(g)(v)]

C. FACILITY-WIDE COMPLIANCE CONDITIONS:

1. Owner/Operator shall allow an authorized representative of the MDAQMD to enter upon the permit holder's premises at reasonable times, with or without notice.
[40 CFR 70.6(c)(2)(i); Rule 1203(D)(1)(g)(i)]
2. Owner/Operator shall allow an authorized representative of the MDAQMD to have access to and copy any records that must be kept under condition(s) of this Federal Operating Permit.
[40 CFR 70.6(c)(2)(ii); Rule 1203(D)(1)(g)(ii)]
3. Owner/Operator shall allow an authorized representative of the MDAQMD to inspect any equipment, practice or operation contained in or required under this Federal Operating Permit.
[40 CFR 70.6(c)(2)(iii); Rule 1203(D)(1)(g)(iii)]
4. Owner/Operator shall allow an authorized representative of the MDAQMD to sample and/or otherwise monitor substances or parameters for the purpose of assuring compliance with this Federal Operating Permit or with any Applicable Requirement.
[40 CFR 70.6(c)(2)(iv); Rule 1203(D)(1)(g)(iv)]
5. Owner/Operator shall remain in compliance with all Applicable Requirements / federally enforceable requirements by complying with all compliance, monitoring, record-keeping, reporting, testing, and other operational conditions contained in this Federal Operating Permit. Any noncompliance constitutes a violation of the Federal Clean Air Act and is grounds for enforcement action; the termination, revocation and re-issuance, or modification of this Federal Operating Permit; and/or grounds for denial of a renewal application.
[1203 (D)(1)(f)(ii)]
6. Owner/Operator shall comply in a timely manner with all applicable requirements / federally - enforceable requirements that become effective during the term of this permit.
[Rule 1201 (I)(2); Rule 1203(D)(1)(g)(v)]
7. Owner/Operator shall insure that all applicable subject processes comply with the provisions of 40 CFR 61, *National Emission Standards for Hazardous Air Pollutants*, subpart A, *General Provisions*, and subpart M, *Asbestos*.
[40 CFR 61, subparts A and M]
8. Owner/Operator shall notify APCO/District at least 10 working days before any applicable asbestos stripping or removal work is to be performed as required by section 61.145.b of

40 CFR 61 subpart M, *National Emission Standard for Asbestos*.
[40 CFR 61.145.b]

9. Owner/Operator shall notify the APCO/District, on an **annual** basis, postmarked by December 17 of the calendar year, of the predicted asbestos renovations for the following year as required by section 61.145.b of 40 CFR 61, subpart M [see cite for threshold triggering and applicability].
[40 CFR 61.145.b]

PART III
EQUIPMENT SPECIFIC APPLICABLE REQUIREMENTS; EMISSIONS
LIMITATIONS; MONITORING, RECORDKEEPING,
REPORTING AND TESTING REQUIREMENTS; COMPLIANCE
CONDITIONS; COMPLIANCE PLANS

1. COMBUSTION TURBINES:

MDAQMD PERMIT NUMBER B005266: COMBUSTION TURBINE GENERATOR 3F-1,
consisting of: Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e).

MDAQMD PERMIT NUMBER B005267: COMBUSTION TURBINE GENERATOR 3F-2,
consisting of: Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e).

MDAQMD PERMIT NUMBER B005268: COMBUSTION TURBINE GENERATOR 3F-3,
consisting of: Natural gas fueled Westinghouse 501F combustion turbine generator power block with a connected heat recovery steam generator and steam condensing turbine, maximum heat input of 1711 MMBtu/hr and producing a nominal 250 MW(e).

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS
RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. Operation of each combustion turbine generator shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. Each combustion turbine generator shall be exclusively fueled with pipeline quality natural gas with a sulfur content not exceeding 0.2 grains per 100 dscf on a rolling twelve month average basis, and shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.

3. Each combustion turbine generator is subject to the federal NSPS codified at 40 CFR Part 60, Subparts A (General Provisions) and GG (Standards of Performance for Stationary Gas Turbines). This equipment is also subject to the Prevention of Significant Deterioration (40 CFR 51.166) and Federal Acid Rain (Title IV) programs. Compliance with all applicable provisions of these regulations is required.
4. Emissions from each combustion turbine generator (including its associated duct burner) shall not exceed the following emission limits at any firing rate, except for CO, NO_x, VOC and ammonia slip during periods of startup, shutdown and malfunction:
 - a. Hourly rates, computed every 15 minutes, verified by CEMS and compliance tests:
 - i. NO_x as NO₂ - 18.00 lb/hr (based on 2.5 ppmvd corrected to 15% oxygen and averaged over one hour)
 - ii. CO - 17.53 lb/hr (based on 4.0 ppmvd corrected to 15% oxygen and averaged over 24 hours)
 - iii. Ammonia Slip - 10 ppmvd (corrected to 15% oxygen and averaged over three hours)
 - b. Hourly rates, verified by compliance tests or other compliance methods in the case of SO_x:
 - i. VOC as CH₄ - 2.51 lb/hr (based on 1 ppmvd corrected to 15% oxygen)
 - ii. SO_x as SO₂ - 1.11 lb/hr (based on LHV), 1.2 lb/hr (based on HHV)
 - iii. PM₁₀ - 18.14 lb/hr

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

5. Emissions of CO and NO_x from the power block (defined as B005266, B005267 and B005268 combined) may exceed the limits contained in Condition 4 during startup and shutdown periods as follows:
 - a. Startup shall be defined as the period beginning with ignition and lasting until the power block has reached operating permit limits. Cold startup means a startup when the power block has not been in operation during the preceding 72 hours. Hot startup means a startup when the power block has been in operation during the preceding 8 hours. Warm startup means a startup that is not a hot or cold startup. Shutdown shall be defined as the period beginning with the lowering of the power block from normal operating load and lasting until fuel flow is completely off and combustion has ceased.
 - b. During a cold startup emissions shall not exceed the following, verified by CEMS:
 - i. NO_x - 549 lb
 - ii. CO - 10,623 lb
 - c. During a warm startup emissions shall not exceed the following, verified by CEMS:
 - i. NO_x - 504 lb
 - ii. CO - 10,788 lb

- d. During a hot startup emissions shall not exceed the following, verified by CEMS:
 - i. NO_x - 414 lb
 - ii. CO - 11,187 lb
- e. During a shutdown emissions shall not exceed the following, verified by CEMS:
 - i. NO_x - 291 lb
 - ii. CO - 717 lb

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

- 6. Emissions from each combustion turbine generator, including the duct burner, may not exceed the following emission limits, based on a calendar day summary:
 - a. NO_x - 848 lb/day, verified by CEMS
 - b. CO - 8072 lb/day, verified by CEMS
 - c. VOC as CH₄ - 1448 lb/day, verified by compliance tests and hours of operation in mode
 - d. SO_x as SO₂ - 26.7 lb/day (based on LHV), 28.8 lb/day (based on HHV), verified by fuel sulfur content and fuel use data
 - e. PM₁₀ - 435 lb/day, verified by compliance tests and hours of operation

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

- 7. Emissions from this facility, including the cooling towers, may not exceed the following emission limits, based on a rolling 12-month summary:
 - a. NO_x - 205 tons/year, verified by CEMS
 - b. CO - 750 tons/year, verified by CEMS
 - c. VOC as CH₄ - 129 tons/year, verified by compliance tests and hours of operation in mode
 - d. SO_x as SO₂ - 14 tons/year (based on LHV), 15.8 tons/year (based on HHV), verified by fuel sulfur content and fuel use data
 - e. PM₁₀ - 233.2 tons/year, verified by compliance tests and hours of operation

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

- 8. Each combustion turbine generator shall exhaust through a stack at a minimum height of 130 feet.
- 9. The owner/operator (o/o) shall not operate each combustion turbine generator without the selective catalytic NO_x reduction system and a VOC and CO oxidation catalyst system with valid District permits installed and fully functional.

10. Emissions of NO_x, CO, oxygen and ammonia slip shall be monitored using a Continuous Emissions Monitoring System (CEMS). Turbine fuel consumption shall be monitored using a continuous monitoring system. The operator shall install, calibrate, maintain and operate these monitoring systems according to a District-approved monitoring plan and Rule 218, and they shall be installed prior to initial equipment startup. Six (6) months prior to installation the operator shall submit a monitoring plan for District review and approval.

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

11. The o/o shall conduct all required compliance/certification tests in accordance with a District-approved test plan. Thirty (30) days prior to the compliance/certification tests the operator shall provide a written test plan for District review and approval. Written notice of the compliance/certification test shall be provided to the District ten (10) days prior to the tests so that an observer may be present. A written report with the results of such compliance/certification tests shall be submitted to the District within forty-five (45) days after testing.
12. The o/o shall perform the following compliance tests in accordance with the MDAQMD Compliance Test Procedural Manual. The test report shall be submitted to the District no later and six weeks prior to the expiration date of this permit. The following compliance tests are required on the specified schedule:
 - a. NO_x as NO₂ in ppmvd at 15% oxygen and lb/hr (measured per USEPA Reference Method 20 or Method 7E performed with Method 3 or 3A to determine NO_x and diluent concentration), at least once every five years 40 CFR 60 Subpart GG Section 60.335(a)
 - b. VOC as CH₄ in ppmvd at 15% oxygen and lb/hr (measured per USEPA Reference Methods 25A and 18), at least once every three years
 - c. SO_x as SO₂ in ppmvd at 15% oxygen and lb/hr, at least once every five years
 - d. CO in ppmvd at 15% oxygen and lb/hr (measured per USEPA Reference Method 10), at least once every five years
 - e. PM₁₀ in lb/hr at 15% O₂ at least once a year (measured per USEPA Reference Methods 5 and 202 or CARB Method 5).
 - f. Ammonia slip in ppmvd at 15% O₂ least once every five years.
 - g. Flue gas flow rate in scfmd, at least once every five years
 - f. Characterization of cold startup VOC emissions, at least once every five years
 - g. Characterization of warm startup VOC emissions, at least once every five years
 - h. Characterization of hot startup VOC emissions; and, at least once every five years
 - i. Characterization of shutdown VOC emissions, at least once every five years
13. Continuous monitoring systems shall meet the following acceptability testing

requirements from 40 CFR 60 Appendix B (or applicable requirements and procedures from 40 CFR 75):

- a. For NO_x, Performance Specification 2.
 - b. For oxygen, Performance Specification 3.
 - c. For CO, Performance Specification 4 or 4a.
 - d. For ammonia, a District-approved procedure that is to be submitted by the o/o.
14. The o/o shall submit to the APCO and USEPA Region IX the following information for the preceding calendar quarter by January 30, April 30, July 30 and October 30 of each year this permit is in effect. Each January 30 submittal shall include a summary of the reported information for the previous year. This information shall be maintained on site for a minimum of five (5) years and shall be provided to District personnel on request:
- a. Operating parameters of emission control equipment, including but not limited to ammonia injection rate, NO_x emission rate and ammonia slip.
 - b. Total plant operation time (hours), hours in cold startup, hours in warm startup, hours in hot startup, and hours in shutdown.
 - c. Average plant operation schedule (hours per day, days per week, weeks per year).
 - d. All continuous emissions data reduced and reported in accordance with the District-approved CEMS protocol.
 - e. Maximum hourly, maximum daily, total quarterly, and total calendar year emissions of NO_x, CO, PM₁₀, VOC and SO_x (including calculation protocol).
 - f. Fuel sulfur content (monthly laboratory analyses, monthly natural gas sulfur content reports from the natural gas supplier(s), or the results of a custom fuel monitoring schedule approved by USEPA for compliance with the fuel monitoring provisions of 40 CFR 60 Subpart GG).
 - g. A log of all excess emissions, including the information regarding malfunctions/breakdowns required by Rule 430.
 - h. Any permanent changes made in the plant process or production, which would affect air pollutant emissions, and indicate when changes were made.
 - i. Any maintenance to any pollutant control system (recorded on an as-performed basis).

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

15. The o/o shall provide sampling ports and platforms necessary to perform source tests required to verify compliance with District rules, regulations and permit conditions. The location of these ports and platforms shall be subject to District approval.

2. DUCT BURNERS:

MDAQMD PERMIT NUMBER B005269: DUCT BURNER 3F-1: COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005266, maximum heat input of 160 MMBtu/hr.

MDAQMD PERMIT NUMBER B005270: DUCT BURNER 3F-2: COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005267, maximum heat input of 160 MMBtu/hr.

MDAQMD PERMIT NUMBER B005271: DUCT BURNER 3F-3: COEN Company, Inc. natural gas burner located within the heat recovery steam generator covered by B005268, maximum heat input of 160 MMBtu/hr.

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be exclusively fueled with natural gas and shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. The duct burner shall not be operated unless operated with the combustion turbine generator with valid District permits as follows. B005269 used with B005266; B005270 used with B005267 and B005271 used with B005268. In addition, selective catalytic NOx reduction systems with valid District permits must be in operation as listed as follows. C005272 serves B005266; C005273 serves B005267; and C005274 serves B005268.
4. Fuel use by this equipment shall be recorded and maintained on site for a minimum of five (5) years and shall be provided to District personnel on request.

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

3. AIR POLLUTION CONTROL EQUIPMENT:

A. SELECTIVE CATALYTIC REDUCTION UNITS

MDAQMD PERMIT NUMBER C005272: SCR UNIT 3F-1: a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005266 and an ammonia injection system.

MDAQMD PERMIT NUMBER C005273: SCR UNIT 3F-2: a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005267 and an ammonia injection system.

MDAQMD PERMIT NUMBER C005274: SCR UNIT 3F-3: a Cormetech selective catalytic reduction system with a catalyst located within the combustion turbine generator covered by B005268 and an ammonia injection system.

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. This equipment shall be operated concurrently with the combustion turbine generators covered in valid permit B005266, B005267, and B005268, as listed above and Part III, item A.
4. Ammonia shall be injected whenever the selective catalytic reduction system has reached or exceeded 550 degrees Fahrenheit except for periods of equipment malfunction. Except during periods of startup, shutdown and malfunction, ammonia slip shall not exceed 10 ppmv dry at 15% oxygen, averaged over three hours.
5. Ammonia injection by this equipment in pounds per hour shall be recorded and maintained on site for a minimum of five (5) years and shall be provided to District

personnel on request.

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

B. OXIDATION CATALYSTS

MDAQMD PERMIT NUMBER C005275: OXIDATION CATALYST 3F-1: High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005266 designed to minimize emissions of VOC and CO.

MDAQMD PERMIT NUMBER C005276: OXIDATION CATALYST 3F-2: High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005267 designed to minimize emissions of VOC and CO.

MDAQMD PERMIT NUMBER C005277: OXIDATION CATALYST 3F-3: High temperature oxidation catalyst manufactured by EmeraChem ADCAT CO Oxidation Catalytic Systems located within the combustion turbine generator covered by B005268 designed to minimize emissions of VOC and CO.

PERMIT CONDITIONS:

PERMIT CONDITIONS; (UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS; VERSION IN SIP = CARB EX. ORDER G-73, 40 CFR 52.220(C)(39)(II)(B) - 11/09/78 43 FR 52237; CURRENT RULE VERSION = 07/25/77:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. This equipment shall be operated concurrently with the combustion turbine generator with valid District permit (C005275 serves B005266; C005276 serves B005267 and C005277 serves B005268; as described above).

4. MISCELLANEOUS FACILITY EQUIPMENT

- A. MDAQMD PERMIT NUMBER E008159: DIESEL IC ENGINE, EMERGENCY FIRE WATER PUMP, consisting of: One Cummins, Diesel fired internal combustion engine, Model No. 6BTA 5.9 FI and Serial No. 46100208, After Cooled, Turbo Charged, producing 182 bhp with 6 cylinders at 1785 rpm while consuming a maximum of 9 gal/hr. This equipment powers a Fire Pump.

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accord with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [40 CFR Part 63, 63.6605(b), 63.6640(a); Rule 204]
2. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:
 - a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
 - b. A cetane index or aromatic content, as follows: 1. A minimum cetane index of 40; or, 2. A maximum aromatic content of 35 volume percent. [17 CCR 93115.5(a) and 40 CFR 80.510(b)] Note: Use of CARB certified ULSD fuel satisfies the above requirements.
3. A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93115; 40 CFR 63.6625(f)]
4. Engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect. [17 CCR 93115; 40 CFR 63.6640(f)]

5. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 30 hours per year for testing and maintenance, excluding compliance source testing. Time required for source testing will not be counted toward the 30 hour per year limit. [17 CCR 93115]

6. The hour limit of Condition #5 can be exceeded when the emergency fire pump assembly is driven directly by a stationary diesel fueled CI engine when operated per and in accord with the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems," 1998 edition. [Title 17 CCR 93115(c)16; 40 CFR 63.6640(f)]

7. The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:
 - a. Date of each use and hours of operation with documentation of how many hours are spent for emergency operation, including what classified the operation as emergency, and how many hours are spent for non-emergency operation, including what classified the operation as non-emergency; and,
 - b. Monthly and calendar year operation in terms of total hours, both emergency and non-emergency use, classified as described in 'a.' above; and,
 - c. Monthly fuel use; and,
 - d. Documentation of certified fuel use, as required by condition 3 (may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
 - e. Maintenance performed on this equipment, inclusive of the management practice requirements of condition 8 below; and,[17 CCR 93115.10(f) and 40 CFR 63.6655(f)]

8. This engine is subject to the requirements of 40 CFR 63, Subpart ZZZZ, and pursuant to this federal regulation, this engine is required to meet the following compliance requirements: The owner/operator of this equipment shall demonstrate continuous compliance by committing to a maintenance schedule inclusive of the management practice requirements listed below:
 - a. Change oil and oil filter every 500 hours of operation or annually, whichever comes first (source has the option to utilize an oil analysis program pursuant to 40 CFR 63.6625(i) in order to extend the specified oil change requirement.);
 - b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and,
 - c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes

first, and replace as necessary. [40 CFR 63.6603(a)]

9. If this emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements required by condition 8, or shutting down the engine would pose an unacceptable risk, the management practice can be delayed until the emergency is over, or the risk has been abated. The management practice should be performed as soon as practicable after the emergency/risk has ended. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63.6603(a)]
 10. The owner/operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes, after which time the emission standards applicable to all times other than startup apply. [40 CFR 63.6625(h)]
 11. This equipment does not require a regularly scheduled emission compliance test. However, emission compliance testing may be required at the discretion of the District. [District Rule 204]
 12. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request.
- B. MDAQMD PERMIT NUMBER E008665: DIESEL IC ENGINE, EMERGENCY GENERATOR, consisting of: One Caterpillar, Diesel fired internal combustion engine, Model No. 3516 and Serial No. 1H202373, After Cooled, Turbo Charged, producing 2848 bhp with 6 cylinders at 1800 rpm while consuming a maximum of 136 gal/hr. This equipment powers a Generator.

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. This equipment shall be installed, operated and maintained in strict accordance with those recommendations of the manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of contaminants. Unless otherwise noted, this equipment shall also be operated in accordance with all data and specifications submitted with the application for this permit. [40 CFR 63.6640(a) and Table 6; Rule 204]

2. This equipment shall only be fired on diesel fuel that meets the following requirements, or an alternative fuel approved by the ATCM for Stationary CI Engines:
 - a. Ultra-low sulfur concentration of 0.0015% (15 ppm) or less, on a weight per weight basis; and,
 - b. A cetane index or aromatic content, as follows: 1. A minimum cetane index of 40; or, 2. A maximum aromatic content of 35 volume percent. [17 CCR 93115.5(a) and 40 CFR 80.510(b)] Note: Use of CARB certified ULSD fuel satisfies the above requirements.
3. A non-resettable hour meter with a minimum display capability of 9,999 hours shall be installed and maintained on this unit to indicate elapsed engine operating time. [Title 17 CCR 93115.10(d); 40 CFR 63.6625(f)]
4. This unit shall be limited to use for emergency power, defined as in response to a fire or when commercially available power has been interrupted. In addition, this unit shall be operated no more than 50 hours per year for testing and maintenance excluding compliance source testing. Time required for compliance source testing will not be counted toward the 50 hour per year limit. [17 CCR 93115.6(b); 40 CFR 63.6640(f)]
5. This unit shall not be used to provide power during a voluntary agreed to power outage and/or power reduction initiated under an Interruptible Service Contract (ISC); Demand Response Program (DRP); Load Reduction Program (LRP) and/or similar arrangement(s) with the electrical power supplier. [17 CCR 93115.6(c)(2); 40 CFR 63.6640(f)]; Rule 204]
6. This engine may operate in response to notification of impending rotating outage if the area utility has ordered rotating outages in the area where the engine is located or expects to order such outages at a particular time, the engine is located in the area subject to the rotating outage, the engine is operated no more than 30 minutes prior to the forecasted outage, and the engine is shut down immediately after the utility advises that the outage is no longer imminent or in effect. [17 CCR 93115.6(b)]
7. The owner/operator shall minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63.6625(h)]
8. The owner/operator shall maintain an operations log for this equipment current and on-site (or at a central location) for a minimum of five (5) years, and this log shall be provided to District, State and/or Federal personnel, upon request. The log shall include, at a minimum, the information specified below:

- a. Date of each use and hours of operation with documentation of how many hours are spent for emergency operation, including what classified the operation as emergency, and how many hours are spent for non-emergency operation, including what classified the operation as non-emergency. and,
 - b. Monthly and calendar year operation in terms of total hours, both emergency and non-emergency use, classified as described in 'a.'; and,
 - c. Monthly fuel use; and,
 - d. Documentation of certified fuel use, as required by condition 2 (may use the supplier's certification of sulfur content if it is maintained as part of this log); and,
 - e. Maintenance performed on this equipment, inclusive of the management practice requirements of condition 8 below; and,
[17 CCR 93115.10(f) and 40 CFR 63.6655(f)]
9. The owner/operator shall conduct inspections in accordance with the following schedule. All inspections must occur at least annually regardless of operating hours.
- a. Change oil and filter every 500 hours of operation or annually, whichever comes first, or use an oil change analysis program to extend oil change frequencies per the requirements in 40 CFR 63.6625(i);
 - b. Inspect air cleaner every 1,000 hours of operation or annually, whichever comes first; and
 - c. Inspect all hoses and belts every 500 hours of operation or annually, whichever comes first, and replace as necessary. The District must be notified within 5 working days of any exceedance of these maintenance intervals, noting the duration, cause, and corrective actions taken. [40 CFR 63.6630(a)]
11. If this emergency engine is operating during an emergency and it is not possible to shut down the engine in order to perform the management practice requirements required by condition 9, or shutting down the engine would pose an unacceptable risk, the management practice can be delayed until the emergency is over, or the risk has been abated. The management practice should be performed as soon as practicable after the emergency/risk has ended. Sources must report any failure to perform the management practice on the schedule required and the Federal, State or local law under which the risk was deemed unacceptable. [40 CFR 63.6603(a)]
12. The facility must submit accurate emissions inventory data to the District, in a format approved by the District, upon District request. [District Rule 204]
13. This engine is subject to the requirements of the Airborne Toxic Control Measure (ATCM) for Stationary Compression Ignition Engines Title 17 CCR 93115 and 40 CFR 63 Subpart ZZZZ (RICE NESHAPs). [Rule 204]

- C. MDAQMD PERMIT NUMBER B005278: COOLING TOWER: Water circulation, treatment and handling equipment and air circulation equipment. Cooling Tower Manufacturer; GEA Integrated Cooling Technologies, Inc. Serial Number; 544246-12B-WCF.

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. Operation of this equipment shall be conducted in compliance with all data and specifications submitted with the application under which this permit is issued unless otherwise noted below.
2. This equipment shall be operated and maintained in strict accord with the recommendations of its manufacturer or supplier and/or sound engineering principles.
3. The drift rate shall not exceed 0.0006 percent with a maximum circulation rate of 218,000 gallons per minute. The maximum hourly PM10 emission rate shall not exceed 1.2 pounds per hour, as calculated per the written District-approved protocol.

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

4. The owner/operator (o/o) shall operate a circulating water monitoring system, which continuously measures the specific conductivity of the circulating water and records the hourly average electronically. The operator shall maintain an electronic log containing the hourly average specific conductivity readings, the average hourly circulating water flow rate, and the resulting average PM10 emission rate (calculated on a weekly basis). This log shall be maintained on site for a minimum of five (5) years and shall be provided to District personnel on request.

[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

5. The o/o shall calculate PM10 emissions in accordance with a District-approved monitoring and emissions calculation protocol. The o/o shall provide a written calculation protocol for District review and approval.
6. A maintenance procedure shall be established that states how often and what procedures will be used to ensure the integrity of the drift eliminators. This procedure is to be kept

on-site and available to District personnel on request.
[40 CFR 70.6 (a)(3)(B) - Periodic Monitoring Requirements]

- D. MDAQMD PERMIT NUMBER T010620: SILOS, BULK STORAGE: Two US Filter Zimpro Products Model T-1 bulk chemical handling station cylindrical silos (soda ash and hydrated lime) each 32 feet 11 1/8" H and 12' diameter that are part of the cooling tower blowdown system. Each silo is equipped with a passive bin vent containing 125 square feet of bag filters that handle 500 cfm of pneumatic loading flow (for an air to cloth ratio of 4:1).

PERMIT CONDITIONS:

PERMIT CONDITIONS; UNLESS OTHERWISE STATED ALL CONDITIONS RESULT FROM RULE 204 - PERMIT CONDITIONS:

1. The owner/operator (o/o) shall maintain this equipment in strict accord with the recommendations of its manufacturer/supplier and/or sound engineering principles which produce the minimum emissions of air contaminants.
2. This equipment shall not be operated unless it is vented through dedicated bin vents when accepting pneumatic fill.
3. The o/o shall conduct a minimum program of inspection and maintenance on this equipment. The o/o shall maintain current and on-site for two (2) years a log of the following information, which shall be provided to District personnel upon request:
 - a. Monthly (or less frequently if observed for every pneumatic fill) binvent stack observation data and result (using USEPA Method 22, and USEPA Method 9 if necessary);
 - b. Annual bag and bag suspension system inspection date and results;
 - c. Date of bag replacements.
 - d. Date and nature of any system repairs.
4. The bin vents shall not discharge into the atmosphere an exhaust stream that exhibits greater than twenty percent opacity.
5. The bin vent shall discharge no more than 0.04 pounds per hour of PM10 at a maximum

concentration of 0.01 grains/dscf at the operating conditions given in the above (BACT). This equipment does not require a regularly scheduled compliance test. However, emission compliance testing may be required at the discretion of the District.

6. The o/o shall maintain on-site a minimum inventory of replacement bags that assures compliance with these conditions.

PART IV
STANDARD FEDERAL OPERATING PERMIT CONDITIONS

A. **STANDARD CONDITIONS:**

1. If any portion of this Federal Operating Permit is found to be invalid by the final decision of a court of competent jurisdiction the remaining portion(s) of this Federal Operating Permit shall not be affected thereby.
[40 CFR 70.6(a)(5); Rule 1203(D)(1)(f)(i)]
2. Owner/Operator shall comply with all condition(s) contained herein. Noncompliance with any condition(s) contained herein constitutes a violation of the Federal Clean Air Act and of MDAQMD Regulation XII and is grounds for enforcement action; termination, revocation and re-issuance, or modification of this Federal Operating Permit; and/or grounds for denial of a renewal of this Federal Operating Permit.
[40 CFR 70.6(a)(6)(i); Rule 1203(D)(1)(f)(ii)]
3. It shall not be a defense in an enforcement action brought for violation(s) of condition(s) contained in this Federal Operating Permit that it would have been necessary to halt or reduce activity to maintain compliance with those condition(s).
[40 CFR 70.6(a)(6)(ii); Rule 1203(D)(1)(f)(iii)]
4. This Federal Operating Permit may be modified, revoked, reopened or terminated for cause.
[40 CFR 70.6(a)(6)(iii); Rule 1203(D)(1)(f)(iv)]
5. The filing of an application for modification; a request for revocation and re-issuance; a request for termination; notifications of planned changes; or anticipated noncompliance with condition(s) does not stay the operation of any condition contained in this Federal Operating Permit.
[40 CFR 70.6(a)(6)(iii); Rule 1203(D)(1)(f)(v)]
6. The issuance of this Federal Operating Permit does not convey any property rights of any sort nor does it convey any exclusive privilege.
[40 CFR 70.6(a)(6)(iv); Rule 1203(D)(1)(f)(vi)]
7. Owner/Operator shall furnish to the MDAQMD, within a reasonable time as specified by the MDAQMD, any information that the MDAQMD may request in writing.

[40 CFR 70.6(a)(6)(v); Rule 1203(D)(1)(f)(vii)]

8. Owner/Operator shall furnish to District, state or federal personnel, upon request, copies of any records required to be kept pursuant to condition(s) of this Federal Operating Permit.
[40 CFR 70.6(a)(6)(v); Rule 1203(D)(1)(f)(viii)]
9. Any records required to be generated and/or kept by any portion of this Federal Operating Permit shall be retained by the facility Owner/Operator for at least five (5) years from the date the records were created.
[40 CFR 70.6(a)(3)(ii)(B); Rule 1203(D)(1)(d)(ii)]
10. Owner/Operator shall pay all applicable fees as specified in MDAQMD Regulation III, including those fees related to permits as set forth in Rules 301 and 312.
[40 CFR 70.6(a)(7); Rule 1203(D)(1)(f)(ix)]
11. Owner/Operator shall not be required to revise this permit for approved economic incentives, marketable permits, emissions trading or other similar programs provided for in this permit.
[40 CFR 70.6(a)(8); Rule 1203(D)(1)(f)(x)]
12. Compliance with condition(s) contained in this Federal Operating Permit shall be deemed compliance with the Applicable Requirement underlying such condition(s). The District clarifies that “only” Applicable Requirements listed & identified elsewhere in this Title V Permit are covered by this Permit Shield and does not extend to any unlisted/unidentified conditions pursuant to the requirements of 40 CFR 70.6(f)(1)(i).
[40 CFR 70.6(f)(1)(i); Rule 1203(G)(1)]
13. The Permit Shield set forth above, in condition 12 of Part IV, shall not be construed to limit the emergency powers of USEPA as set forth in 42 U.S.C. §7603.
[40 CFR 70.6(f)(3)(i); Rule 1203(G)(3)(a)]
14. The Permit Shield set forth above, in condition 12 of Part IV, shall not be construed to limit liability for violations, which occurred prior to the issuance of this Federal Operating Permit.
[40 CFR 70.6(f)(3)(ii); Rule 1203(G)(3)(b)]
15. The Permit Shield set forth above, in condition 12 of Part IV, shall not be construed to alter any Applicable Requirement Contained in the Acid Rain Program.
[40 CFR 70.6(f)(3)(iii); Rule 1203(G)(3)(c)]
16. The Permit Shield set forth above, in condition 12 of Part IV, shall not be

construed to limit the ability of USEPA or the MDAQMD to obtain information pursuant to other provisions of law including but not limited to 42 U.S.C. §7414. [40 CFR 70.6(f)(3)(iv); Rule 1203(G)(3)(d)]

17. The Permit Shield set forth above, in condition 12 of Part IV, shall not be construed to apply to emissions trading pursuant to provisions contained in an applicable State Implementation Plan.
[40 CFR 70.4(b)(12)(ii)(B); Rule 1203(G)(3)(e)]
18. The Permit Shield set forth above, in condition 12 of Part IV, shall not be construed to apply to changes made which are not expressly allowed by this Federal Operating Permit.
[40 CFR 70.4(b)(14)(iii); Rule 1203(G)(3)(f)]
19. The Permit Shield set forth in Part IV, condition 12, shall not be construed to apply to changes made pursuant to the Significant Permit Modification provisions until such changes are included in this Federal Operating Permit.
[40 CFR 70.5(a)(1)(ii), 70.7(e)(2)(vi); Rule 1203 (G)(3)(g)]
20. If Owner/Operator performs maintenance on, or services, repairs, or disposes of appliances, Owner/Operator shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. These requirements are Federally Enforceable through this Title V Permit.
[40 CFR Part 82, Subpart F]
21. If Owner/Operator performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), Owner/Operator shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. These requirements are Federally Enforceable through this Title V Permit.
[40 CFR Part 82, Subpart B]
22. Notwithstanding the testing requirements contained elsewhere in this Title V Permit, any credible evidence may be used to establish violations, including but not limited to; reference test methods, engineering calculations, indirect estimates of emissions, CEMS data, and parametric monitoring data. Data need not be required to be collected in a Title V permit in order to be considered credible.
[Section 113(a) of the Clean Air Act]

PART V OPERATIONAL FLEXIBILITY

A. ALTERNATIVE OPERATING SCENARIO (S):

B. OFF PERMIT CHANGES:

I. Permittee may make a proposed change to equipment covered by this permit that is not expressly allowed or prohibited by this permit if:

A. Permittee has applied for and obtained all permits and approvals required by MDAQMD Regulation II and Regulation XII unless the equipment involved in the change is exempt from obtaining such permits and approvals pursuant to the provisions of Rule 219; and

1. The proposed change is not:

- a. Subject to any requirements under Title IV of the Federal Clean Air Act; or *[See 1203(E)(1)(c)(i)d]*
- b. A modification under Title I of the Federal Clean Air Act; or
- c. A modification subject to Regulation XIII; and *[See 1203(E)(1)(c)(i) d]*
- d. The change does not violate any Federal, State or Local requirement, including an applicable requirement; and *[See 1203(E)(1)(c)(i)c]*
- e. The change does not result in the exceedance of the emissions allowable under this permit (whether expressed as an emissions rate or in terms of total emissions). *[See 1203(E)(1)(c)(i)e]*

II. Procedure for “Off Permit” Changes

A. If a proposed “Off Permit Change” qualifies under Part V, Section (B)(I)(A)(1) above, permittee shall implement the change as follows:

1. Permittee shall apply for an Authority To Construct permit pursuant to the provisions of Regulation II. *[See 1203(E)(1)(c)(i)b]*

2. In addition to the information required pursuant to the provisions of Regulation II and Regulation XIII such application shall include:

- a. A notification that this application is also an application for an “Off Permit” Change pursuant to this condition; and *[See 1203(E)(1)(c)(i)b]*
- b. A list of any new Applicable Requirements which would apply as a result of the change; and *[See 1203(E)(1)(c)(i)b.]*
- c. A list of any existing Applicable Requirements, which would cease to apply as a result of the change. *[See 1203(E)(1)(c)(i)c]*

3. Permittee shall forward a copy of the application and notification to USEPA upon submitting it to the District. *[See 1203(E)(1)(c)(i)a]*
 - B. Permittee may make the proposed change upon receipt from the District of the Authority to Construct Permit or thirty (30) days after forwarding the copy of the notice and application to USEPA whichever occurs later. *[See 1203(E)(1)(c)(i)a and g]*
 - C. Permittee shall attach a copy of the Authority to Construct Permit and any subsequent Permit to Operate, which evidences the Off Permit Change to this Title V permit. *[See 1203(E)(1)(c)(i)ff]*
 - D. Permittee shall include each Off-Permit Change made during the term of the permit in any renewal application submitted pursuant to Rule 1202(B)(3)(b). *[See 1203(E)(1)(c)(i)ff]*
- III. Other Requirements:
- A. The provisions of Rule 1205 – Modifications do not apply to an Off Permit Change made pursuant to this condition.
 - B. The provisions of Rule 1203(G) – Permit Shield do not apply to an Off Permit Change made pursuant to this condition. *[See 40 CFR 70.4(b)(i)(B)]*
[Rule 1203(E)(1)(c)]

PART VI
TITLE IV ACID RAIN PERMIT

Effective Dates: September 18, 2016 through September 18, 2021

Issued to: HIGH DESERT POWER PROJECT, LLC

Plant Site Location: 19000 Perimeter Road
Victorville, CA 92394

Type of Facility: Combined Cycle Generation Facility

Primary SIC: 4911 – Electric Power Generation

ORIS Code: 55518

DESIGNATED REPRESENTATIVE

Name: Mark Kubow

Title: President

FACILITY CONTACT PERSON

Name: Jon Boyer

Title: Environmental Manager

ACID RAIN PERMIT CONTENTS

- 1) PERMIT APPLICATION - see page VI-59
The owners and operators of the source must comply with the standard requirements and special provisions set forth in the application submitted for this source.
- 2) Applicable Requirements
 - a. SO₂ allowance allocated under this permit and NO_x requirements for each affected unit:

	9/18/16-9/18/21
SO2 allowances under Table 2 of 40 CFR Part 73	None
NOx limit, 40 CFR Part 76	none

b. Standard Requirements

Citation	Requirement
40 CFR 72 Rule 1210	Owner/Operator of High Desert Power Project, LLC shall comply with all applicable provisions of 40 CFR 72, Permits Regulation (Title IV) and their Title IV permit application as indicated in this combined, Federal Operating Permit / Title IV Acid Rain Permit, Part VIII.
40 CFR 72 Rule 1210	Owner / Operator shall comply with <i>all listed compliance conditions contained within this Title IV Acid Rain Permit and associated Title V Permit.</i>
40 CFR 70.6(a)(1)(ii)	Where an applicable requirement of the Act is more stringent than an applicable requirement of Title IV regulations, both provisions shall be incorporated into the permit and is enforceable by the Administrator.
Monitoring, 40 CFR Part 72, Section 72.9(b)	<p>1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in part 75 of this chapter.</p> <p>(2) The emissions measurements recorded and reported in accordance with part 75 of this chapter shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions</p>

	<p>reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.</p> <p>(3) The requirements of part 75 of this chapter shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.</p>
Reporting, 40 CFR Part 72, Section 72.9(f)(2)	<p>The designated representative of an affected source and each affected unit at the source shall submit the reports and compliance certifications required under the Acid Rain Program, including those under subpart I of this part and part 75 of this chapter.</p>
Recordkeeping, 40 CFR Part 72, Section 72.9(f)(1)	<p>(1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority.</p> <p>(i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with §72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission of a new certificate of representation changing the designated</p>

	<p>representative.</p> <p>(ii) All emissions monitoring information, in accordance with part 75 of this chapter; provided that to the extent that part 75 provides for a 3-year period for recordkeeping, the 3-year period shall apply.</p> <p>(iii) Copies of all reports, compliance certifications, and other submissions and all records made or required under the Acid Rain Program.</p> <p>(iv) Copies of all documents used to complete an Acid Rain permit application and any other submission under the Acid Rain Program or to demonstrate compliance with the requirements of the Acid Rain Program.</p>
Section 113(a) of the Clean Air Act	<p>Notwithstanding the testing requirements contained elsewhere in this combined Title IV / V Permit, any credible evidence may be used to establish violations, including but not limited to; reference test methods, engineering calculations, indirect estimates of emissions, CEMS data, and parametric monitoring data. Data need not be required to be collected in a Title V permit in order to be considered credible.</p>

3) Statement of Basis

The Mojave Desert Air Quality Management District issues this permit pursuant to Regulation XII, Rule 1210 and Titles IV and V of the Clean Air Act. Questions or comments regarding this permit should be addressed to:

Brad Poiriez, Executive Director

Mojave Desert Air Quality Management District
 14306 Park Avenue
 Victorville, CA 92392
 760-245-1661
 760-245-2022 (fax)

This Acid Rain Permit applies to the following units:

MDAQMD PERMIT NUMBER	DESCRIPTION	BASIS
B005266 B005269	COMBUSTION TURBINE 3F-1 DUCT BURNER 3F-1	40 CFR Part 72.6(a)(3)(i)
B005267 B005270	COMBUSTION TURBINE 3F-2 DUCT BURNER 3F-2	40 CFR Part 72.6(a)(3)(i)
B005268 B005271	COMBUSTION TURBINE 3F-3 DUCT BURNER 3F-3	40 CFR Part 72.6(a)(3)(i)

Comments, notes and justifications regarding this Acid Rain Program permit

- Pursuant to 40 CFR Part 72.6(a)(3)(i), the affected units specified above meet the 72.2 definition for a new utility unit and are subject to the acid rain permit requirements of 72.9(a). The affected units do not qualify for a new unit exemption pursuant to 40 CFR 72.7(b)(1) since each serves a generator with a nameplate capacity greater than 25 MW.
- The affected units specified above are not listed in table-2 of 40 CFR Part 73, therefore, the operator is not required to obtain SO₂ allowances under the Acid Rain Program.
- This unit is not subject to the NO_x requirements from 40 CFR Part 76 as this unit is not capable of firing on coal

Facility (Source) Name (from STEP 1)

Permit Requirements

STEP 3

Read the standard requirements.

- (1) The designated representative of each affected source and each affected unit at the source shall:
 - (i) Submit a complete Acid Rain permit application (including a compliance plan) under 40 CFR part 72 in accordance with the deadlines specified in 40 CFR 72.30; and
 - (ii) Submit in a timely manner any supplemental information that the permitting authority determines is necessary in order to review an Acid Rain permit application and issue or deny an Acid Rain permit;
- (2) The owners and operators of each affected source and each affected unit at the source shall:
 - (i) Operate the unit in compliance with a complete Acid Rain permit application or a superseding Acid Rain permit issued by the permitting authority; and
 - (ii) Have an Acid Rain Permit.

Monitoring Requirements

- (1) The owners and operators and, to the extent applicable, designated representative of each affected source and each affected unit at the source shall comply with the monitoring requirements as provided in 40 CFR part 75.
- (2) The emissions measurements recorded and reported in accordance with 40 CFR part 75 shall be used to determine compliance by the source or unit, as appropriate, with the Acid Rain emissions limitations and emissions reduction requirements for sulfur dioxide and nitrogen oxides under the Acid Rain Program.
- (3) The requirements of 40 CFR part 75 shall not affect the responsibility of the owners and operators to monitor emissions of other pollutants or other emissions characteristics at the unit under other applicable requirements of the Act and other provisions of the operating permit for the source.

Sulfur Dioxide Requirements

- (1) The owners and operators of each source and each affected unit at the source shall:
 - (i) Hold allowances, as of the allowance transfer deadline, in the source's compliance account (after deductions under 40 CFR 73.34(c)), not less than the total annual emissions of sulfur dioxide for the previous calendar year from the affected units at the source; and
 - (ii) Comply with the applicable Acid Rain emissions limitations for sulfur dioxide.
- (2) Each ton of sulfur dioxide emitted in excess of the Acid Rain emissions limitations for sulfur dioxide shall constitute a separate violation of the Act.
- (3) An affected unit shall be subject to the requirements under paragraph (1) of the sulfur dioxide requirements as follows:
 - (i) Starting January 1, 2000, an affected unit under 40 CFR 72.6(a)(2); or
 - (ii) Starting on the later of January 1, 2000 or the deadline for monitor certification under 40 CFR part 75, an affected unit under 40 CFR 72.6(a)(3).

Facility (Source) Name (from STEP 1)

Sulfur Dioxide Requirements, Cont'd.

STEP 3, Cont'd.

- (4) Allowances shall be held in, deducted from, or transferred among Allowance Tracking System accounts in accordance with the Acid Rain Program.
- (5) An allowance shall not be deducted in order to comply with the requirements under paragraph (1) of the sulfur dioxide requirements prior to the calendar year for which the allowance was allocated.
- (6) An allowance allocated by the Administrator under the Acid Rain Program is a limited authorization to emit sulfur dioxide in accordance with the Acid Rain Program. No provision of the Acid Rain Program, the Acid Rain permit application, the Acid Rain permit, or an exemption under 40 CFR 72.7 or 72.8 and no provision of law shall be construed to limit the authority of the United States to terminate or limit such authorization.
- (7) An allowance allocated by the Administrator under the Acid Rain Program does not constitute a property right.

Nitrogen Oxides Requirements

The owners and operators of the source and each affected unit at the source shall comply with the applicable Acid Rain emissions limitation for nitrogen oxides.

Excess Emissions Requirements

- (1) The designated representative of an affected source that has excess emissions in any calendar year shall submit a proposed offset plan, as required under 40 CFR part 77.
- (2) The owners and operators of an affected source that has excess emissions in any calendar year shall:
 - (i) Pay without demand the penalty required, and pay upon demand the interest on that penalty, as required by 40 CFR part 77; and
 - (ii) Comply with the terms of an approved offset plan, as required by 40 CFR part 77.

Recordkeeping and Reporting Requirements

- (1) Unless otherwise provided, the owners and operators of the source and each affected unit at the source shall keep on site at the source each of the following documents for a period of 5 years from the date the document is created. This period may be extended for cause, at any time prior to the end of 5 years, in writing by the Administrator or permitting authority:
 - (i) The certificate of representation for the designated representative for the source and each affected unit at the source and all documents that demonstrate the truth of the statements in the certificate of representation, in accordance with 40 CFR 72.24; provided that the certificate and documents shall be retained on site at the source beyond such 5-year period until such documents are superseded because of the submission

PART VII CONVENTIONS, ABBREVIATIONS, DEFINITIONS

A. CONVENTIONS

The following referencing conventions are used in this federal operating permit:

- 40 CFR Part 60, Standards of Performance for New Stationary Sources (NSPS)
- 40 CFR Part 60, Appendix F, Quality Assurance Procedures
- 40 CFR Part 61, National Emission Standards for Hazardous Air Pollutants (NESHAPS)
- 40 CFR Part 61, Subpart M, National Emission Standards for Asbestos
- 40 CFR Part 63--National Emission Standards For Hazardous Air Pollutants For Affected Source Categories
- 40 CFR Part 72, Permits Regulation (Acid Rain Program)
- 40 CFR Part 73, Sulfur Dioxide Allowance System
- 40 CFR Part 75, Continuous Emission Monitoring
- 40 CFR Part 75, Subpart D, Missing Data Substitution Procedures
- 40 CFR Part 75, Appendix B, Quality Assurance and Quality Control Procedures
- 40 CFR Part 75, Appendix C, Missing Data Estimating Procedures
- 40 CFR Part 75, Appendix D, Optional SO₂ Emissions Data Protocol
- 40 CFR Part 75, Appendix F, Conversion Procedures
- 40 CFR Part 75, Appendix G, Determination of CO₂ Emissions

B. OTHER CONVENTIONS:

1. Unless otherwise noted, a “day” shall be considered a 24-hour period from midnight to midnight (i.e., calendar day).
2. The process unit identifications represent the District permit number designations. These numbers are not sequential. The use of District permit numbers provides continuity between the District and Federal Operating Permit systems.

C. ABBREVIATIONS

Abbreviations used in this permit are as follows:

CFR	Code of Federal Regulations
APCO	Air Pollution Control Officer
bhp	brake horsepower
Btu	British thermal units
CCR	California Code of Regulations
CEMS	continuous emissions monitoring system
CO	carbon monoxide

CO ₂	carbon dioxide
District	Mojave Desert Air Quality Management District (formed July 1993)
MDAQMD	Mojave Desert Air Quality Management District (formed July 1993)
MD	Mojave Desert Air Quality Management District (formed July 1993)
SB	San Bernardino County APCD (1975 to formation of MDAQMD)
gr/dscf	grains per dry standard cubic foot
gpm	gallons per minute
gph	gallons per hour
hp	horse power
H&SC	California Health and Safety Code
lb	pounds
lb / hr	pounds per hour
lb / MM Btu	pounds per million British thermal units
MM Btu	million British thermal units
MM Btu/hr	million British thermal units per hour
MW	Megawatt electrical power
MW(e) net	net Megawatt electrical power
NH ₃	ammonia
NMOC	non-methane organic compounds
NO _x	oxides of nitrogen
NO ₂	nitrogen dioxide
O ₂	oxygen
pH	pH (acidity measure of solution)
PM ₁₀	particulate matter less than 10 microns aerodynamic diameter
ppmv	parts per million by volume
psig	pounds per square inch gauge pressure
QA	quality assurance
rpm	revolutions per minute
RVP	Reid vapor pressure
SCAQMD	South Coast Air Quality Management District
scfm	standard cubic feet per minute
scfh	standard cubic feet per hour
SIC	Standard Industrial Classification
SIP	State of California Implementation Plan
SO _x	oxides of sulfur
SO ₂	sulfur dioxide
tpy	tons per year
TVP	true vapor pressure

D. SIP Rule Citations for Mojave Desert Air Quality Management District Rules

District Rule Number	District Rule Title	SIP Rule Version	SIP Citation	Federally Enforceable
203	<i>Permit to Operate</i>	1/7/77	Approved 11/9/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 40 CFR 52.220(c)(31)(vi)(C)	Y
204	<i>Permit Conditions</i>	1/9/76	Approved 11/9/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 40 CFR 52.220(c)(31)(vi)(C)	Y
206	<i>Posting of Permit to Operate</i>	1/9/76	Approved 11/9/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 40 CFR 52.220(c)(31)(vi)(C)	Y
207	<i>Altering or Falsifying of Permit</i>	1/9/76	Approved 11/09/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 52.220(c)(31)(vi)(C)	Y
209	<i>Transfer and Voiding of Permit</i>	1/9/76	Approved 11/9/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 40 CFR 52.220(c)(31)(vi)(C)	Y
217	<i>Provision for Sampling And Testing Facilities</i>	1/9/76	Approved 11/9/78, 43 FR 52237, 40 CFR 52.220(c)(39)(ii)(B) and 40 CFR 52.220(c)(31)(vi)(C)	Y
218	<i>Stack Monitoring</i>	7/25/79	Approved 9/28/81, 46 FR 47451, 40 CFR 52.220(c)(65)(ii)	Y

MDAQMD Federal Operating Permit
 High Desert Power Project Federal Operating Permit # - 104701849
 Last Revised: November 19, 2018

219	<i>Equipment Not Requiring a Written Permit</i>	6/6/77	Approved 11/9/78, 43 FR, 52237, 40 CFR 52.220(c)(31)(vi)(C), 40 CFR 52.220(c)(32)(iv)(C), and 40 CFR 52.220(c)(39)(ii)(B)	Y
221	<i>Federal Operating Permit Requirement</i>	12/21/94	Approved 2/5/96, 61 FR 4217, 40 CFR 52.220(c)(216)(i)(A)(2)	Y
301	<i>Permit Fees</i>	Not in SIP	Applicable Version = Most current amendment, Applicable via Title V Program interim approval 02/05/96 61 FR 4217	Y
312	<i>Fees for Federal Operating Permits</i>	Not in SIP	Applicable Version = Amended: 12/21/94, Applicable via Title V Program interim approval 02/05/96 61 FR 4217	Y
401	<i>Visible Emissions</i>	7/25/1977	Approved 9/8/78, 43 FR 4001, 40 CFR 52.220(c)(39)(ii)(C)	Y

MDAQMD Federal Operating Permit
 High Desert Power Project Federal Operating Permit # - 104701849
 Last Revised: November 19, 2018

403	<i>Fugitive Dust</i>	7/25/1977	Approved 9/8/78, 43 FR 4001, 40 CFR 52.220(c)(39)(ii)(B)	Y
403.2	<i>Fugitive Dust Control for the Mojave Desert Planning Area</i>	9/22/96	Approved 12/9/98, 63 FR 67784, 40 CFR 52.220(c)(194)(i)(H)(1)	Y
404	<i>Particulate Matter Concentration</i>	7/25/77	Approved 12/21/78, 43 FR 59489, 40 CFR 52.220(c)(42)(xiii)(A)	Y
405	<i>Solid Particulate Matter, Weight</i>	7/25/77	Approved 12/21/78, 43 FR 59489, 40 CFR 52.220(c)(42)(xiii)(A) ; Approved 6/14/78, 43 FR 25684, 40 CFR 52.220(c)(32)(iv)(A)	Y
406	<i>Specific Contaminants</i>	7/25/197 (subdivision (a))	Approved, 12/21/78, 43 FR 59489, 40 CFR 52.220(c)(42)(xiii)(A)	Y
407	<i>Liquid and Gaseous Air Contaminants</i>	5/7/76	Approved 9/8/78, 43 FR 40011; 40 CFR 52.220(c)(39)(ii)(C)	Y

MDAQMD Federal Operating Permit
High Desert Power Project Federal Operating Permit # - 104701849
Last Revised: November 19, 2018

408	<i>Circumvention</i>	5/7/76	Approved 9/8/78, 43 FR 40011; 40 CFR 52.220(c)(39)(ii)(C); Approved 6/14/78, 43 FR 25684, 40 CFR 52.220(c)(32)(iv)(A)	Y
409	<i>Combustion Contaminants</i>	5/7/76	Approved 9/8/78; 43 FR 40011; 40 CFR 52.220(c)(39)(ii)(C); Approved 6/14/78, 43 FR 25684, 40 CFR 52.220(c)(32)(iv)(A)	Y
430	<i>Breakdown Provisions</i>	Not in SIP	Applicable Version = Amended: 12/21/94, Applicable via Title V Program interim approval 02/05/96 61 FR 4217	Y
431	<i>Sulfur Content of Fuels</i>	10/8/1976	Approved 9/8/1978, 43 FR 40011, 40 CFR 52.220(c)(37)(i)(B) and 40 CFR 52.220(c)(39)(ii)(B)	Y
442	<i>Usage of Solvents</i>	2/27/06	Approved 09/17/2007, 72 FR 52791, 40 CFR 52.220(c)(347)(i)(C)(1)	Y
900	<i>Standards of Performance for New Stationary Sources</i>	2/28/11	Delegated by USEPA	Y

MDAQMD Federal Operating Permit
 High Desert Power Project Federal Operating Permit # - 104701849
 Last Revised: November 19, 2018

1000	<i>National Emissions Standards from Hazardous Air Pollutants</i>	2/28/11	Delegated by USEPA	Y
1104	<i>Organic Solvent Degreasing Operations</i>	9/28/94	Approved: 4/30/96, 61 FR 18962, 40 CFR 52.220(c)(207)(I)(D)(2)	Y
1113	<i>Architectural Coatings</i>	4/23/12	Approved: 1/03/14, 79 FR 364, 40 CFR 52.220(c)(428)(i)(C)	Y
1115	<i>Metal Parts and Products Coating Operations</i>	4/22/96	Approved 12/23/97, 62 FR 67002, 40 CFR 52.220(c)(239)(i)(A)(2)	Y
1161	<i>Cement Kilns</i>	3/25/02	Approved 1/2/02, 67 FR 19, 40 CFR 52.220(c)(287)(i)(A)(1)	Y
1302	<i>NSR - Procedure</i>	3/25/96	Approved 11/13/1996, 61 FR 58133, 40 CFR 52.220(c)(239)(i)(A)(1)	Y
Regulation XII	<i>Federal Operating Permits</i>	1201-1210: 9/26/05 1200 & 1211: 2/28/11	SIP: Not SIP. Final Title V Program Approval 11/21/03 68 FR 65637; Partial Withdrawal of approval 10/15/02 67 FR 63551; Notice of Deficiency 05/22/02 67 FR 35990; Approval 12/17/01 66 FR 63503; Interim	

MDAQMD Federal Operating Permit
High Desert Power Project Federal Operating Permit # - 104701849
Last Revised: November 19, 2018

			Approval 02/05/96 61 FR 4217	
--	--	--	---------------------------------	--